



#### NOTES:

1. END OF PIPE AT PROPERTY LINE TO BE PLUGGED.
2. STORM SERVICE CONNECTION PIPE TO BE FITTED WITH APPROVED RUBBER GASKET JOINTS.
3. IF CONTRACTOR TUNNELS UNDER WATERMAIN, MINIMUM LENGTH OF TUNNEL TO BE 1.83m AND ALL VOIDS TO BE FILLED WITH 10 MPa. CONCRETE.
4. VERTICAL BEND AT PIPE JOINT NOT TO EXCEED 5°.
5. RISERS TO BE INSTALLED WHERE SPECIFIED ON THE ENGINEERING DRAWINGS OR WHEN DEPTH TO TOP OF SEWER EXCEEDS 4.50m.
6. GRADE OF PIPE APPROACHING PROPERTY LINE TO BE 2%.
7. SERVICE CONNECTION TO BE INSTALLED IN A STRAIGHT LINE FROM SEWER TO STREETLINE.
8. THIS STANDARD IS NOT APPLICABLE FOR CONNECTIONS GREATER THAN 250mm Ø.
9. ALL DIMENSIONS ARE IN MILLIMETRES OR METRES.
10. FLOOR DRAIN CONNECTIONS WITHIN BUILDING ENVELOPE SHALL NOT BE CONNECTED TO STORM SEWER SERVICE.
11. POLYVINYL CHLORIDE PIPE (SDR 26) IS AN APPROVED EQUIVALENT TO CONCRETE PIPE SERVICE CONNECTIONS.
12. AS AN ALTERNATE 'KOR-N-TEE' CONNECTORS MAY BE USED FOR 150mm AND 200mm DIAMETER STORM DRAIN CONNECTIONS.
13. THE ELEVATION OF THE BASEMENT FLOOR MUST BE AT LEAST 0.6m ABOVE THE STORM SEWER OBVERT AND 0.6m ABOVE THE 1:100 YEAR STORM HYDRAULIC GRADELINE FOR THE SITE

APPROVED	TOWNSHIP OF UXBRIDGE	DATE OF ISSUE JANUARY 1980
REVISION 1		DRAWING No.
DATE OF REVISION MAY, 2005	STORM SEWER SERVICE CONNECTION	US-165