

## NOTES

- 1 MINIMUM CONC STRENGTH SHALL BE 20MPa 2 BEDDING MATERIAL SHALL BE 19mm CLEAR
- STONE OR EQUIVALENT
- 3 SPLASH PAOS TO BE USED IN AREAS WHICH ARE DESIGNATED BY THE TWP ENGINEER
  - 4 ALL DIMENSIONS ARE IN MILLIMETRES OR METRES UNLESS OTHERWISE SPECIFIED

APPROVED	TOWNSHIP OF UXBRIDGE	JANUARY 1980
REVISION	PRECAST CONCRETE	DRAWING NO.

DATE OF REVISION

SPLASH PAD DETAIL

US-302