



CROSS SECTION

NOTE

1. ALL DIMENSIONS ARE IN MILLIMETRES OR METRES.
2. SECURITY LIGHTING OF WALKWAYS TO BE PROVIDED. DESIGN OF LIGHTING SYSTEM WILL BE SUBJECT TO APPROVAL BY THE TOWNSHIP OF UXBRIDGE.

3. ALL CONCRETE WORK TO CONFIRM TO THE REQUIREMENT OF OPSD-1350. CLASS OF CONCRETE: 30 MPa, 5-7% AIR ENTRAINMENT, 20mm MAXIMUM AGGREGATE SIZE.

4. MAXIMUM EXPANSION JOINT SPACING TO BE 4.5m.
5. CONCRETE POST FOOTINGS TO BE SEPARATE FROM CURB.

APPROVED

REVISION

2

DATE OF REVISION
MAY 2005

TOWNSHIP OF UXBRIDGE

PEDESTRIAN WALKWAY

DATE OF ISSUE

JANUARY 1980

DRAWING No.

US-320